NOTES: 1. All dimensions are in millimetres unless otherwise stated. 300 256 The Earth electrode pit can either be constructed of concrete or from a high performance polymer and must be sited in concrete foundation 158 PVC insulated Earth conductor in accordance with BS 7671 : 2001 connected to the main Earth terminal in the pillar or column 70-3 No 1.2m x 11.2mm copper clad rods Larger diameter rods to be used where ground conditions are adverse Leicestershire County Council

©Crown copyright 2007. All rights reserved. Use of this image is limited to viewing on-line and printing one copy. Leicestershire County Council 40004074.



TRANSPORTATION AND WASTE MANAGEMENT

TITLE:

STANDARD DRAWING

STREET LIGHTING

EARTH PIT AND ELECTRODE DETAIL

DRAWING NUMBER	DATE				100019271.
SD/14/8	APRIL 2007				
AUTOCAD REF	SCALE				
K:\GENERAL\D9997STDDRG\SD1	48 NOT T	TO SCALE	Rev	Date	Notes on Revision